

PERMIT TO CONSTRUCT

Onsite Wastewater System

File Nor 2021100017

County: Lexington

Name: TYLER SGRO

Type Facility: HOUSE

Address: 4524 ORR STREET

NORTH CHARLESTON, SC 29405

Program Code: 360 System Code: 100

TM No.: 010920-01-023

Subdivision:

Block:

Lot:

Site: VICTOR RD GASTON, SC

Water Supply: PRIVATE

PERMIT TO CONSTRUCT SYSTEM SPECIFICATIONS

Daily Flow (gpd): 480

Tank Sizes (gal): Septic Tank: 1000 Pump Chamber:

Grease Trap:

LTAR: 90

Trenches: Length (ft): 178

Width (in): 36

Max. Depth (in); 33

Agg. Depth (in): 14

Min Pump Capacity:

gpm at

ft. of head Alternative Product:

SPECIAL INSTRUCTIONS/CONDITIONS

THIS PERMIT IS SITE SPECIFIC. ANY CHANGES TO THE SYSTEM MUST BE APPROVED BY DHEC, ALTERNATIVE TRENCH PRODUCTS APPROVED UNDER STATE RULES AND REGULATIONS MAY BE SUBSTITUTED. ANY UNAPPROVED CHANGES WILL VOID THIS PERMIT.

Installers must contact the local Environmental Affairs office by 10:00 AM on the day prior to installation in order to schedule a time for the final inspection.

If a Department representative does not arrive within 30 minutes of the scheduled time, the installer may conduct the final inspection.

When a contractor self-inspection occurs, the installer must complete the DHEC form 3978, Approval to Operate Contractor Self-inspection.


The installer must submit DHEC form 3978 within 2 business days of the completion of the installation.

All applicable setbacks set forth in Regulation 61-56 apply.

Maximum Trench Deoth not to exceed 33 inches.

* A lift pump maybe needed if gravity flow from septic tank cannot be achieved.

X SOTI WOOK + Septile System



Issued/Revised By:

 \mathcal{E} w au

This Permit is Appealable Under the Administrative Procedures Act.

This permit will expire and become null and void five (5) years from the issuance date.

There may be an Additional Fee for Changes in this Permit that Require a Site Reevaluation.