



PERMIT TO CONSTRUCT
Onsite Wastewater System

File Nbr: 2021100053
County: Horry

Name: TYLER SGRO
Type Facility: MOBILE HOME
Subdivision:
Block: Lot:

Address: 4524 ORR ST
N. CHARLESTON, SC 29405
Site: LITTLE BETHEL RD
GREENSEA, SC

Program Code: 362
System Code: 270
TM No.: 12905030006
Water Supply: PRIVATE

PERMIT TO CONSTRUCT SYSTEM SPECIFICATIONS

Daily Flow (gpd): 360 Tank Sizes (gal): Septic Tank: 1000 Pump Chamber: Grease Trap:
LTAR: .50 Trenches: Length (ft): 130 Width (in): 120 Max. Depth (in): 9 Agg. Depth (in): 6
Min Pump Capacity: gpm at ft. of head Alternative Product: (10' wide)

SPECIAL INSTRUCTIONS/CONDITIONS

THIS PERMIT IS SITE SPECIFIC. ANY CHANGES TO THE SYSTEM MUST BE APPROVED BY DHEC. ALTERNATIVE TRENCH PRODUCTS APPROVED UNDER STATE RULES AND REGULATIONS MAY BE SUBSTITUTED. ANY UNAPPROVED CHANGES WILL VOID THIS PERMIT.
Installers must contact the local Environmental Affairs office by 10:00 AM on the day prior to installation in order to schedule a time for the final inspection.
If a Department representative does not arrive within 30 minutes of the scheduled time, the installer may conduct the final inspection.
When a contractor self-inspection occurs, the installer must complete the DHEC form 3978, Approval to Operate Contractor Self-Inspection.
The installer must submit DHEC form 3978 within 2 business days of the completion of the installation.

See Attached Page...

PERMIT TO CONSTRUCT SYSTEM DIAGRAM

(NTS)

Please See Attached Pages.

(Page 1 of 3)

Issued/Revised By: [Signature] Shayla Ebert

Date: 11/12/2021

DHEC 1781 (02/2020)

This Permit is Appealable Under the Administrative Procedures Act.
This permit will expire and become null and void five (5) years from the issuance date.
There may be an Additional Fee for Changes in this Permit that Require a Site Reevaluation.



**PERMIT TO CONSTRUCT AND OPERATE
Onsite Wastewater System**

File Number: 2021100053
County: Horry

SPECIAL INSTRUCTIONS/CONDITIONS

THIS PERMIT IS SITE SPECIFIC. ANY CHANGES TO THE SYSTEM MUST BE APPROVED BY DHEC. ALTERNATIVE TRENCH PRODUCTS APPROVED UNDER STATE RULES AND REGULATIONS MAY BE SUBSTITUTED. ANY UNAPPROVED CHANGES WILL VOID THIS PERMIT.

Installers must contact the local Environmental Affairs office by 10:00 AM on the day prior to installation in order to schedule a time for the final inspection. If a Department representative does not arrive within 30 minutes of the scheduled time, the installer may conduct the final inspection. When a contractor self-inspection occurs, the installer must complete the DHEC form 3978, Approval to Operate Contractor Self-Inspection. The installer must submit DHEC form 3978 within 2 business days of the completion of the installation.


This Permit to Construct is issued based on a soil report submitted by Professional Soil Classifier Tyler Sgro, licensed number 119, dated 10/26/2021.

The plumbing stub-out elevation and location must be compatible with the system design. The maximum trench depth of the system trenches noted on the permit may not be increased to accommodate for a plumbing stub-out that has been installed too low to be compatible with the system design. DHEC is not responsible for setting a plumbing stub-out elevation.

The trenches for this system design are 10' wide.

Install two 65'-long trenches on level grade with a maximum depth of 9" at any point in the drain field area. Use imported fill dirt to create a fill cap with 5' buffer beyond the trenches and 5'-10' taper back to the natural ground elevation. The fill cap is to provide 12" of ground cover over the aggregate after final grading.

(Page 2 of 3)

Issued/Revised By:  Shayla Ebert

Date: 11/12/2021

