

## PERMIT TO CONSTRUCT **Onsite Wastewater System**

File Nbr:2022030013

County: Orangeburg

Name: TYLER SGRO

Type Facility: MOBILE HOME

Subdivision:

Block:

Lot:

Address: 4524 ORR ST

NORTH CHARLESTON, SC 29405

ELLOREE, SC 29047

Site: CITY POINT RD LOT 3

TM No.: 282-00-02-006

Program Code: 362

System Code: 270

Water Supply: PRIVATE

PERMIT TO CONSTRUCT SYSTEM SPECIFICATIONS

Tank Sizes (gal): Septic Tank: 1000

Pump Chamber:

Grease Trap:

LTAR: 40

Trenches: Length (ft): 216

Width (in): 120

Max. Depth (in):

Agg. Depth (in): 6

Min Pump Capacity:

Daily Flow (gpd): 480

gpm at

ft. of head Alternative Product:

## SPECIAL INSTRUCTIONS/CONDITIONS


THIS PERMIT IS SITE SPECIFIC. ANY CHANGES TO THE SYSTEM MUST BE APPROVED BY DHEC. ALTERNATIVE TRENCH PRODUCTS APPROVED UNDER STATE RULES AND REGULATIONS MAY BE SUBSTITUTED. ANY UNAPPROVED CHANGES WILL VOID THIS PERMIT.

Installers must contact the local Environmental Affairs office by 10:00 AM on the day prior to installation in order to schedule a time for the final inspection. If a Department representative does not arrive within 30 minutes of the scheduled time, the installer may conduct the final inspection.

When a contractor self-inspection occurs, the installer must complete the DHEC form 3978, Approval to Operate Contractor Self-Inspection. The installer must submit DHEC form 3978 within 2 business days of the completion of the installation.

MAXIMUM DEPTH 18 INCHES @ DATA POINT 1 AND 15 INCHES @ DATA POINT 2.

IF GRAVITY FLOW FROM TANK TO DRAIN LINES CANNOT BE OBTAINED WITHOUT EXCEEDING MAXIMUM DEPTHS, A PUMP SYSTEM WILL HAVE TO BE INSTALLED.



Per: Soils RePort by Tyler SGro, SCPSC # 119 DHEC 1781 (02/2020)

This Permit is Appealable Under the Administrative Procedures Act. This permit will expire and become null and void five (5) years from the issuance date.

There may be an Additional Fee for Changes in this Permit that Require a Site Reevaluation.